



Lake Kiowa Special Utility District

133 Kiowa Dr. S.
Lake Kiowa, TX 76240-9539
(Tel) 940-668-8391 (Fax) 940-668-6637
www.lksud.org



Routine Monitoring Violation Total Coliform Rule

Lake Kiowa Special Utility District failed to collect the required number of bacteriological samples for coliform monitoring of the water distribution system during the following periods: Jan. 2017, Feb. 2017, Mar. 2017. This monitoring is required by the Texas Commission on Environmental Quality's "Drinking Water Standards" and the federal "Safe Drinking Water Act," Public Law 95-523. Bacteriological samples are used to monitor water quality and indicate if the water is free of coliform bacteria. Our water system is required to submit four (4) bacteriological samples each month. Failure to collect all required bacteriological samples is a violation of the monitoring requirements and we are required to notify you of this violation. If you have any questions regarding this violation, you may contact Lake Kiowa Special Utility District at (940) 668-8391.

What Should I do?

There is nothing you need to do at this time. You do **NOT** need to boil your water or take other actions.

What is being done?

We were notified by the state that based on the population numbers they were using. The correct number of samples taken should have been four (4). We did take three (3) samples, which were all received back absent of coliform or e-coli bacteria.

These violations were caused by the state using a default population number of three (3) persons per residence, which required LKSUD to take an additional sample. The population numbers have been corrected with the TCEQ and the required number of samples has now been reduced.

For more information. Please contact Ronny Young, General Manager LKSUD at (940) 668-8391 or 133 Kiowa Dr. S. Lake Kiowa TX 76240.

- Please share this information with all other people who drink this water, especially those who may not have received this notice directly.

This notice is being sent to you by Lake Kiowa Special Utility District. State Water System ID# 0490016